

Bid invitation

Information

Description:EMN1/1060017465/96 INCH SHOT

BLAST M/C

Bid invitation number:6300029084

Version: 1

Bid invitation rules

Bid invitation currency: INR

Timezone: UTC+53

Submission period: 10.09.2019 17:00:00

Opening date: 10.09.2019 17:00:00

Created On: 26.08.2019 06:35:46

Bid invitation text:

GENERAL TERMS & CONDITIONS:

1. Delivery Terms: FDD/ FOR BEML, KGF.
2. Payment Terms: Payment will be processed after certification from Electrical Maintenance Dept.
3. Micro & small enterprise bidders to indicate Udyog Adhaar Memorandum number (UAM) and declaration of UAM on CPPP in their bid.
4. Quote should be valid for minimum 60 days from the date of Bid opening. Bids with validity of less than 60 days are liable for rejection.
5. Firm to indicate GSTIN and applicable GST in their bid.
6. Firm to indicate HSN code for the items in the bid invitation.
7. Firm to indicate the time requirement for supply.
8. Warranty : One year
9. Firm to indicate complete specification and other connected details in their bid.
10. L-1 evaluation will be based on landed cost of technically accepted bids.

NOTE:-

- 1) In e- Bidding system - If you need any type of assistance, Please contact Mr. Krishna Mohan (Ph No – 080-22963269 / 22963141& Email – admin.srm@beml.co.in).
- 2) Please contact given below mail IDs for any type of technical clarification.
 - i) ese@beml.co.in & ii) em5@beml.co.in

Attachments:

Drawing 1

Drawing 2

Bid invitation

Information

Description:EMN1/1060017465/96 INCH SHOT
BLAST M/C

Bid invitation number:6300029084

Version: 1

Attachments:

Drawing 3

Digital Signature

Bid invitation details

Item	Product Price Condition	Description	Vendor product number	Delivery date/ performance period	Quantity
1	008731980385	Electrical Panel-96 inch Shot Blast M/C		00:00:00	1 NO

Item long text:

Electrical Control Panel for 96 inch swing table shot Blasting Machine

Specification for Electrical Control Panel for 96-inch swing table shot Blasting Machine

1). Combined Control Center Power & Control Panel Consisting of:

a).DOL/STAR DELTA starters of suitable capacity, Overload relays, fuses, terminals, control circuit transformer, push buttons, indicating lamps, timers, toggle & one common main line disconnect switch to be provided.

b). Operational desk will be inclusive of all necessary power control and operating devices like start & stop push button, selectorswitches ,toggle swiches indicating instruments ammeters for main wheel drives and main voltmeter, indicating lamps. As per drawing No.ESE-2/LW/SB-001.

c). Power & control circuit wiring: PVC insulated, copper wires inside the panel of suitable capacity with colour coding and indications.

d). Electrical interlocking to be provided for safety and machine operation.

e). All the instruments & accessories in front of control cubical will be thick mounted.

Note:

1.Power contactors, OLR's, MPCB's, Toggle switches, Push Buttons (ON/OFF), Emergency Stop Button, Main ON Rotary Switch, Star Deltastars, selector switches indicting Lamps, power and control switch gear wiring. (All switch Gears of SIEMENS MAKE).

HRC fuses: Standard/ Havells/Indoasian.Wires: Finolex/ V-guard/Havells.

2. Panels: Fabricated from 2MM thick sheet & dust and vermi proof.

3. Painting: The inner surfaces with white enamel & outer surface with Sea Green over a coat of red-oxide.

Bid invitation

Information
 Description:EMN1/1060017465/96 INCH SHOT
 BLAST M/C
 Bid invitation number:6300029084
 Version: 1

Item	Product Price Condition	Description	Vendor product number	Delivery date/ performance period	Quantity
------	-------------------------	-------------	-----------------------	-----------------------------------	----------

4.Red, Yellow & Blue colour wires have to be used for internal wiring for the 3 phases & the same to be clamped in box type plasticenclosures. All the wiring will be properly secured, and each wire will have distinct marking/numbering. Suitable locking to be provided for the panel doors.

General Note:

- 1.Firm may visit our works for any clarifications before submission of technical bid.
- 2.Firm has to supply the panel as per the Electrical control drawings provided by BEML. Further the firm has to forward the Electrical /GA drawings of switch gear items for necessary approval against receipt of PO.
- 3.Three SETS of Electrical Drawings to be submitted during material supply.
- 4.Firm has to carry out Installation, Commission & prove out the performance of the panel.
5. Payment will be processed after certification from user department.
6. Warranty: One Year

Basic Price	INR	_____
CGST - Central GST	%	_____
IGST -Integrated GST	%	_____
SGST - State GST	%	_____
UTGST	%	_____