

## Bid invitation

### Information

Description:EMN1/1060018550/200W INDUCTION  
HIGH BAY

Bid invitation number:6300034648

Version: 1

### Bid invitation rules

Bid invitation currency: INR

**Timezone:** UTC+53

**Submission period:** 11.11.2020 17:00:00

**Opening date:** 11.11.2020 17:00:00

**Created On:** 21.10.2020 03:38:42

### Bid invitation text:

#### GENERAL TERMS & CONDITIONS:

1. Delivery Terms: FDD/ FOR BEML, KGF.
2. Payment Terms: 60 days from receipt, acceptance & commissioning against certification by Plant Maintenance dept. For Micro / Small Enterprises, it is 45 days.
3. Micro & small enterprise bidders to indicate Udyog Adhaar Memorandum number (UAM) and declaration of UAM on CPPP in their bid.
4. Quote should be valid for minimum 60 days from the date of Bid opening. Bids with validity of less than 60 days are liable for rejection.
5. Firm to indicate GSTIN and applicable GST in their bid.
6. Firm to indicate HSN code for the items in the bid invitation.
7. Firm to indicate the time requirement for supply & commissioning.
8. Warranty : 5 Years from the date of installation or 5 1/2 years from the date of supply.
9. Firm to indicate complete specification and other connected details in their bid and firm should quote only for the MAKES indicated in the Bid Invitation.
10. L-1 evaluation will be based on item wise landed cost of technically accepted bids.

#### NOTE:-

- 1) In e- Bidding system - If you need any type of assistance, Please contact Mr. Krishna Mohan (Ph No – 080-22963269 / 22963141& Email – admin.srm@beml.co.in).
- 2) Please contact given below mail IDs for any type of technical clarification.
  - i) ese@beml.co.in & ii) em5@beml.co.in

Attachments:

# Bid invitation

## Information

Description:EMN1/1060018550/200W INDUCTION HIGH BAY

Bid invitation number:6300034648

Version: 1

Attachments:

Digital Signature

## Bid invitation details

Item	Product Price Condition	Description	Vendor product number	Delivery date/ performance period	Quantity
1	000106092065	200W INDUCTION HIGH BAY LUMINARIE		00:00:00	50 NO

### Item long text:

The 200W Induction lamps are required for replacement of existing 400W HPMV lamps at HighEnd Excavator assembly and HES shops as apart of Energy Conservation project.

200 watts Induction Lamp with Driver & Fixture suitable for  
Highbay Light application  
SPECIFICATION OF 200W HIGH BAY INDUCTION LUMINARIES.

1. WATTAGE : 200W
2. WORKING VOLTAGE RANGE : 100-270V AC
3. POWER FACTOR : 0.96
4. LIGHT SOURCE TYPE : CIRCULAR
5. LUMENS : 26000
6. OPERATING TEMPERATURE : 25 DEG. C ABOVE AMBIENT
7. PROTECTION CLASS : IP54 / IP65
8. COLOUR RENDERING INDEX (CRI) : 80
9. FIXING ARRANGEMENT : TO BE SECURED THROUGH HOOK/BRACKET
- 10.USAGE : 16 HRS / DAY
- 11.FIXTURE : FIXTURE: MADE OF HIGH PR. DIE-CAST ALUMINIUM WITH STATIC PLASTIC  
SPRAYED/ELECTROPLATED SURFACE
12. GASKET : MADE OF HIGH QUALITY SILICON NEOPRENE MATERIAL FOR SUPERIOR PROTECTION
13. REFLECTOR: ELECTRO CHEMICALLY TREATED, HIGH REFLECTIVITY REFLECTOR USING HIGH  
PURITY ALUMINIUM.
- 14.MAINTENANCE : ZERO MAINTENANCE FOR TROUBLE FREE OPERATION.
- 15.MAKE: KAREE/LVD/PRO-LITE/BAJAJ/MAHINDRA/TEJ/BOLT

### NOTE:

1. FIRM MAY VISIT OUR WORKS TO STUDY THE SUITABILITY OF INDUCTION FITTING BEFORE  
SUBMITTING THE OFFER.
2. THE LIGHTING SYSTEM SHOULD CONFORM /COMPLIANT WITH ALL RELEVANT STANDARDS (IS) &  
CERTIFIED BY CE, UL, ULC, CCC, FCC, KET, ISO9001:2000, CEEMC,CPRI, ERDA, ROHS, EN62532,

# Bid invitation

Information  
 Description:EMN1/1060018550/200W INDUCTION HIGH BAY  
 Bid invitation number:6300034648  
 Version: 1

Item	Product Price Condition	Description	Vendor product number	Delivery date/ performance period	Quantity
		IEC61347 OR EQUIVALENT LATEST STANDARDS. FIRM SHOULD SUBMIT THE COPIES OF REPORT ALONG WITHSUPPLY.			
		3. FIRM HAS TO REMOVE THE EXISTING LUMINARIES AND COMMISSION THE INDUCTION LIGHT FITTINGS WITH NECESSARY MODIFICATIONS WITHOUT EXTRA COST.			
		4. INDUCTION LIGHT FIXTURES SHOULD BE GUARANTEED FOR A MINIMUM PERIOD OF 5 (FIVE) YEARS FROM THE DATE OF INSTALLATION OR 5 ½ YEARS FROM THE DATE OF SUPPLY. WARRANTY CERTIFICATE IS TO BE FURNISHED.			
		5. BEML WILL ARRANGE FOR POWER SHUT DOWN DURING THE WORK AND FIRM MAY USE THE EXISTING EOT CRANE FOR INSTALLATION WORKS.			
		6. NECESSARY SAFETY PRECAUTIONS FOR THE LABORERS ENGAGED ARE THE RESPONSIBILITY OF THE FIRM. IN CASE OF ANY INJURY/MISHAPS, BEML WILL NOT OWN ANY RESPONSIBILITY TO THE LABOR WHILE CARRYING OUT THE WORK.			

CGST - Central GST	%	_____
Basic Price	INR	_____
IGST -Integrated GST	%	_____
SGST - State GST	%	_____
UTGST	%	_____