

Bid invitation

Information

Description:EMN2/Supply& Inst of Main free Earthing

Bid invitation number:6300035671

Version: 1

Bid invitation rules

Bid invitation currency: INR

Timezone: UTC+53

Submission period: 16.03.2021 17:00:00

Opening date: 16.03.2021 17:00:00

Created On: 09.03.2021 05:46:04

Bid invitation text:

GENERAL TERMS AND CONDITIONS

1. Delivery Terms: FDD/FOR BEML, KGF.
2. Payment Terms: 60 Days from receipt & acceptance of item. For Micro/ Small Enterprises, it is 45 Days.
3. Micro & Small enterprise bidders to indicate Udyog Aadhar Memorandum number (UAM) and declaration of UAM on CPPP in their bid.
4. Quote should be valid for minimum 60days from the date of Bid opening. Bids with validity of less than 60 days are liable for rejection.
5. Firm to indicate GSTIN and applicable GST in their Bid.
6. Firm to indicate HSN CODE for the items in the items in the Bid invitation
7. Firm to indicate the time requirement for supply.
8. Warranty for the material to be specified.
9. Firm to indicate complete specification and other connected details in their Bid.
10. L-1 evaluation will be based on landed cost of technically accepted Bids.

NOTE:-

1. In e-Bidding system – if you need any type of assistance, please contact Mr. Krishna Mohan (Ph No.080-22963269/22963141 & Email-admin.srm@beml.co.in)
2. Please contact given below mail Ids for any type of technical clarification.

i)emnkgf@beml.co.in

ii)hn@beml.co.in

iii)gse@beml.co.in

=====

Bid invitation

Information
Description:EMN2/Supply& Inst of Main free Earthing
Bid invitation number:6300035671
Version: 1

MAINTENANCE FREE GI EARTHING ELECTRODE: 50/25

ITEM SPECIFICATION:

1. 50/25MM Dia Dual Pipe With Flat Technology Earthing Electrode of One SET comprises of 1.3Mtr Long 45-50MM Dia Outer Pipe
2. 24-25MM Dia Inner Pipe
3. Terminal Flat of 30x12x12 MM
4. The Entire Construction processed with Hot Dip Galvanization. Outer Strip up to 100 Microns (Min) and all Inner Surfaces up to 200 to 300Microns. All inner annular space filled with highly conductive and noncorrosive nature crystalline Material.
5. Electrode Moisture Booster compound of 50 KG per Earth pit should be supplied to fill the surrounding of the Pipe at the Time ofInstallation. Moisture Booster should have a property of Moisture retention, conduction and Non-Corrosive Nature.
6. With Chrome plated Bolts, Nuts & Washers for Connection
7. For use in Body Earthing.

=====

SCOPE OF WORK:

1. Digging of Soil to the required Depth for installation of Supplied 50/25 MM GI Earthing Electrodes
2. Installation/ Erection of Earthing Electrode
3. Filling of soil & Terminal Flat End Connection.
4. Measuring & Report of Earth Resistance.
5. Prove out of Earth resistance with less than 5 Ohms.

Attachments:

Bid invitation

Information

Description:EMN2/Supply& Inst of Main free Earthing
 Bid invitation number:6300035671

Version: 1

Attachments:

Digital Signature

Bid invitation details

Item	Product	Description	Vendor product number	Delivery date/ performance period	Quantity
1	8700223115	MAINT. FREE GI EARTHING ELECTRODE: 50/25		00:00:00	10.000 SET
	CGST - Central GST	%			
	UTGST	%			
	Basic Price	INR			
	SGST - State GST	%			
2		Installation & Commissioning Charges			1 AU
	CGST - Central GST	%			
	UTGST	%			
	Basic Price	INR			
	SGST - State GST	%			