

CORRIGENDUM# 1 TO TENDER 6300029905

PART A – TECHNICAL SPECIFICATIONS & CONDITIONS

Description : Supply, Installation and Commissioning of **500 KVA Silent Type Diesel Generator set.**

FOR :

Sl. No	Description	Specifications(FOR)	Specifications(READ AS)
1	Diesel Engine	Fuel Efficiency: 230 milligrams to 235 milligrams / KW/ HOUR.	Fuel Efficiency/consumption Up to 235 grams / KW/ HOUR.
2	Exhaust System:	The firm has to make provision for Exhaust system with suitable silencer along with standard Length with mounting stand, as per requirement of Pollution control board norms.	The firm has to make provision for Exhaust system with suitable silencer along with standard Length of exhaust pipe as per manufacturers standard
3	Other terms and conditions	a. Standard/Manual Control panel with DG controller with AutoStart, auto stop, manual start, manual stop facility to be provided by the firm b. Diesel required during testing and commissioning shall be provided by BEML c. Any spares required like filters, lube oils etc with in the warranty period is in Firms scope d. Certificate from pollution control board to be provided e. DG set supplier has to coordinate with AMF panel supplier for the satisfactory working of the complete system. (500KVA DG Set and AMF Panel) f. Unloading of DG set is in BEML scope	

The tender has been extended till 14.11.2019

Tender reference in 6300029905 in BEML SRM

Bidders to note the above corrigendum and quote accordingly.

Bidders to comply accordingly in **ANNEXURE I-COMPLIANCE**