

CORRIGENDUM-1


Supply, Installation & commissioning of Industrial Air Compressor

(Tender Ref. No.: 6300030139)

This has the reference to the Pre-bid meeting which was conducted on 22.11.2019 at ASMD. The following amendment is incorporated in the technical specification. Hence corrigendum is released.

	For	Read As
SCOPE	Supply, Installation, Commissioning, Testing and Performance prove out of One No. Stationary, base mounted, oil injected, air cooled type screw compressor with all electrical accessories & variable frequency drive of capacity: 600cfm (550 to 650 cfm)	Supply, Installation, Commissioning, Testing and Performance prove out of One No. Stationary, base mounted, oil injected, air cooled type screw compressor with all electrical accessories & variable frequency drive of capacity: 600cfm (550 to 650 cfm). The scope includes to construct a suitable shed to cover the installed compressor at the proposed location.
Make	Frank Air Compressor / Kirloskar Pneumatic / Chicago Pneumatic / Atlas Copco / ELGI / KAESER / Ingersoll Rand / KG KHOSLA ltd / KOBELCO	Frank Air Compressor / Kirloskar Pneumatic / Chicago Pneumatic / Atlas Copco / ELGI / KAESER / Ingersoll Rand / KG KHOSLA ltd / KOBELCO / FSCURTIS
Delivery Schedule	Delivery of the complete system to be completed within 60 days from the date of release of Purchase Order. However, the firm to quote their best delivery schedule for supply and installation & commissioning of the item	Delivery of the complete system to be completed within 90 days from the date of release of Purchase Order. However, the firm to quote their best delivery schedule for supply and installation & commissioning of the item
Paint	The equipment with accessories should be neatly painted preferably with Blue color to shade RAL 5015 after necessary pretreatment	The equipment with accessories should be neatly painted as per the OEM standard . However, the air piping to be painted with Blue color to shade RAL 5015 after necessary pretreatment
Bid submission due date & Time	06.12.2019 @ 14:00 Hours	13.12.2019 @ 14:00 Hours
Technical Bid opening due date & Time	06.12.2019 @ 14:00 Hours	13.12.2019 @ 14:00 Hours

All other terms and conditions of the tender uploaded earlier remains the same. Minutes of Pre-Bid meeting is attached at Annexure to Corrigendum.


Deputy General Manager
ASMD-Planning
MYSORE Complex