

## CORRIGENDUM-1


### Supply of Cold Storage Unit (Qty: 1 No)

(Tender Ref. No.: 6300030454)

Pre-bid meeting was scheduled on 12/12/2019 at ASMD, Mysore. No firms have attended the pre-bid meeting. Based on the clarifications / feedback received from various firms through email regarding the tender on cold storage unit, the following amendment is incorporated in the technical specification. Hence corrigendum is released.

Sl. No.	Description	Requirement	
		For	Read As
02	Model	Floor model with front side door opening	Floor model with front side door opening and <b>which is suitable for the total refrigeration / cooling load of 50kg Aluminium sheet metal components</b>
03	Effective working chamber size (min)	2000mm x 2000mm x 2000mm (H x W x D)	Minimum 2000mm x 2000mm x 2000mm (H x W x D) – <b>(Internal Dimensions). Trolley and basket of Stainless-steel material to be supplied to suit the chamber size</b>
05	Temperature Display	Dual display to view the processing & set temperature simultaneously	Dual display to view the processing <b>time</b> & set temperature simultaneously. <b>Electronic temperature recorder to be provided</b>
09	Temperature Uniformity	Shall be maintained by forced air circulation for uniformity of temperature better than $\pm 1^{\circ}\text{C}$ within the chamber	Shall be maintained by forced air circulation for uniformity of temperature better than $\pm 3^{\circ}\text{C}$ within the chamber
21	Set temperature	Shall reach set temperature within 45 minutes	<b>Set temperature shall be achieved within 20 minutes after loading the aluminium sheet metal components</b>

All other terms and conditions of the tender uploaded earlier remains the same.

  
Deputy General Manager  
ASMD-Planning  
BEML Ltd.  
MYSORE Complex