

**Corrigendum II**  
**TENDER NO.6300030822**

Subject: High bay lights – 4 Types in BEML Limited, Bangalore Complex, Bangalore-75

With reference to the above referred subject tender, the following details are brought to the notice of bidders:

	Description(FOR)	Description(READ AS)
0112016562	70 WATTS LED HIGH BAY FITTING	70 WATTS LED HIGH BAY FITTING. TOTAL RATED WATTAGE : 70 WATTS INPUT VOLTAGE RANGE : 100 TO 270 VOLTS COLOUR OF LED : COOL WHITE TYPE OF LED'S : HI-POWERED CIRCUIT PROTECTION : OVER VOLTAGE, SHORT CIRCUIT, SURGE AND SPIKE PROTECTIONS. COMPLIANCE STANDARDS : AS PER LM79 & LM80 AND TEST REPORTS TO BE FURNISHED FROM NABL ACCREDITED LAB. WARRANTY : THREE (3) YEARS
0112016572	90 WATTS LED HIGH BAY FITTING	90 WATTS LED HIGH BAY FITTING. TOTAL RATED WATTAGE : 90 WATTS INPUT VOLTAGE RANGE : 100 TO 270 VOLTS COLOUR OF LED : COOL WHITE TYPE OF LED'S : HI-POWERED CIRCUIT PROTECTION : OVER VOLTAGE, SHORT CIRCUIT, SURGE AND SPIKE PROTECTIONS. COMPLIANCE STANDARDS : AS PER LM79 & LM80 AND TEST REPORTS TO BE FURNISHED FROM NABL ACCREDITED LAB. WARRANTY : THREE (3) YEARS
0112016582	120 WATTS LED HIGH BAY FITTING	120 WATTS LED HIGH BAY FITTING. TOTAL RATED WATTAGE: 120 WATTS INPUT VOLTAGE RANGE: 100 TO 270 VOLTS COLOUR OF LED: COOL WHITE TYPE OF LED'S: HI-POWERED CIRCUIT PROTECTION: OVER VOLTAGE, SHORT CIRCUIT, SURGE AND SPIKE PROTECTIONS. COMPLIANCE STANDARDS: AS PER LM79 & LM80 AND TEST REPORTS TO BE FURNISHED FROM NABL ACCREDITED LAB. WARRANTY: THREE (3) YEARS

0112016592	HIGH BAY LED FIXTURE, 150 WATTS	150 WATTS LED HIGH BAY FITTING WITH FOLLOWING SPECIFICATIONS: RATED WATTAGE: 150 WATTS FREQUENCY: 50HZ +/- 10% COLOR OF LED: COOL WHITE THD: 10% to 15% POWER FACTOR: >0.90 SYSTEM EFFICIENCY: > 90 LUMENS / WATT APPROXIMATE IP: 65/66 PROTECTION: SURGE, OPEN AND SHORT CIRCUIT PROTECTION. THE LM 79 AND LM 80 TEST REPORTS FROM NABL ACCREDIATED LAB TO BE SUBMITTED. GUARANTEE: TWO YEARS.
------------	------------------------------------	--

Bidders to note the above corrigendum and quote accordingly.

This ADDENDUM-1 Forms a part of the tender document and has to be sealed and signed by all bidders and uploaded along with their technical bid.